



PRODUCT PERFORMANCE REPORT

Document ID 1524997242

Issued on April 29th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Lämpötilamestarit Oy**
 Company **Lämpötilamestarit Oy**
 Project reference **Lämpötilamestarit Oy**
 Project location **Finland**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.135**
 Brand **TOSHIBA**
 Range **DSK9**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **RAS-25PAVPG-ND/RAS-25PKVPG-ND**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	61	dB(A)
Lw1 env	57	dB(A)
Bivalent Point		
Tbiv	-10	Å°C
COP @ Tbiv	3.0	
Ph TBiv	3.0	kW
General		
Mounting	High Wall	
MPS	230-1-50	
Refrigerant	R32	
Refr. Line	5.0 m	m
Heating 14511		
Ph @+7	3.2	kW
COP @+7	5.33	
Heating Average Climate		
Pdesignh	3.0	kW
SCOP	5.3	
SCOP Class	A+++	
Qhe	792.0	kWh/annum
Poffc		
Poff	0.8	W
Psbcc		



PRODUCT PERFORMANCE REPORT

Document ID 1524997242

Issued on April 29th, 2018

FEATURE	VALUE	UNIT
Psb	0.8	W
Ptoc		
Pto	29.2	W
Seasonal Efficiency in Cooling		
Pdesignc	2.5	kW
SEER	9.0	
SEER Class	A+++	
Qce	97.0	kWh/annum
Thermal		
EER @+35	5.21	
TOL Runing Test		
TOL	-30.0	Â°C
COP @ TOL	2.0	
Ph @ TOL	2.3	kW